


Technical  
Information



<b>INTRODUCTION</b>	About this manual .....	3
	Applicable documents.....	3
	References .....	3
	Definitions and abbreviations.....	3
<b>SYSTEM</b>	System overview.....	4
	System context.....	4-6
	System design .....	7
<b>DESIGN and INTERACTION</b>	Decomposition description.....	8
	CAN-identifier usage.....	8-10
	Variable identifier usage define with CAN-shield .....	8
	Predefined identifier usage with fixed N1 .....	10
	Fixed identifier usage .....	10
	KWP2000 node and net assignments .....	10
	KWP2000 node number .....	10
	KWP2000 net number .....	10
	LED handling.....	10
	Red LED .....	10
Green LED .....	10	

*Revision history*

Revision date	Page	Change	Remarks
12/16/2005			Initial release

© 2005 Sauer-Danfoss. All rights reserved. Printed in U.S.A.

Sauer-Danfoss accepts no responsibility for possible errors in catalogs, brochures and other printed material. Sauer-Danfoss reserves the right to alter its products without prior notice. This also applies to products already ordered provided that such alterations aren't in conflict with agreed specifications. All trademarks in this material are properties of their respective owners. Sauer-Danfoss, the Sauer-Danfoss logotype, PLUS+1 and PLUS+1 logo are trademarks of the Sauer-Danfoss Group. Bosch is a registered trademark of Robert Bosch GmbH.

Front cover illustrations: F101421, F101422, F101423, F101425, 2326

**ABOUT THIS MANUAL**

This publication explains the protocol design of the PLUS+1 CAN I/O communication. It will show the necessary parts of the design and their interaction.

*Applicable documents*

<b>DM</b>	SPRS1741 (i)	TMS320F2810 TMS320F2812 - Digital Signal Processors Data Technical Information (Texas Instruments)
-----------	--------------	--

*References*

<b>SFS</b>	D-270405-1, 1.14	Smart Flash loader Specification (Smart GmbH)
<b>DS301</b>	DS301, 4.00	Application Layer and Communication Profile CiA (CAN in Automation)
<b>2.0</b>	CAN2spec, 2.00	CAN Specification (Bosch®)
<b>J1939</b>	Data Link Layer	Surface Vehicle Recommended Practice – J1939-21 (SAE)

*Definitions and abbreviations*


<b>CAN</b>	Controller Area Network
<b>CRC</b>	Cyclic Redundancy Check
<b>CPU</b>	Central Processing Unit
<b>ECU</b>	Electronic Control Unit
<b>EEPROM</b>	Electrically Erasable and Programmable Read Only Memory*
<b>Kernel</b>	Set of hardware dependant driver functions and operating system
<b>OTP</b>	One-Time Programmable
<b>RAM</b>	Random Access Memory
<b>ROM</b>	Read Only Memory
<b>LSB</b>	Least Significant Byte
<b>MSB</b>	Most Significant Byte
<b>PDO</b>	Process Data Object (CAN Open Terminology) [DS301]
<b>Tx</b>	Transmit
<b>Rx</b>	Receive
<b>I/O</b>	Input/Output
<b>MC</b>	Master Controller in the network (for example: MC024-010 or MC050-010)
<b>0x</b>	In front of a number defines a base 16 number (hexadecimal)
<b>CAN-Bx</b>	CAN Data Byte number X, counting of these bytes start from zero

\* This phrase is still used, even if the selected device is re-programmable

#### SYSTEM OVERVIEW

Besides the programmable members of the microcontroller family like the MC024-010 and MC050-010, the PLUS+1 platform needs different I/O expander modules. There is always the chance that some additional requirements will need extra inputs or outputs to the system. If the controllers already in the system are out of I/O, it may make sense to add an inexpensive I/O module to the system rather than stepping up to a higher performance controller.

#### CAN-architecture



2323

#### SYSTEM CONTEXT


#### PLUS+1 family with five different I/O units

IX012-010-00000	12 pin input
IX024-010-00000	24 pin input
OX012-010-00000	12 pin output
OX024-010-00000	24 pin output
IOX012-10-00000	12 pin input/output

You can use more than one I/O device in the same network. It is also possible in *Sauer-Danfoss only networks\** to replace one unit without additional service actions.

#### CAN-bus with several PLUS+1 MC and I/O Modules

#### Service tool interface



2324

The I/O modules have a *bootloader* program. You can update the firmware using the PLUS+1 service and diagnostic tool. Use the *downloader* from the *service tool* to load a new .lhx file.

\**Sauer-Danfoss only network* means that only PLUS+1 compliant units are connected on the CAN-bus.


**SYSTEM CONTEXT  
 (CONTINUED)**

**Service tool interface (continued)**

You can also use the service tool to change the default addressing mode of the I/O modules. This might be necessary in some circumstances. The service tool and the desired I/O module must be the only devices on the CAN-bus. You can also use the service tool to monitor the configuration and status of the outputs.

To use the service tool, you must first save the *diagnostic (.p1h)* file for the specific I/O module hardware that you are using. This file is available under the *misc files* in the *hardware tab* on the right side of the PLUS+1 GUIDE screen. Right click on the file and save it to your local hard drive.

*PLUS+1 miscellaneous files screen example*




2229

Now that the file is saved to the local hard drive, open it with the service tool.

Remember that it is a .p1h file, not a .p1d file. (.p1h indicates that it is associated with a particular hardware, not an application.)

When you open the .p1h file you may get the following dialog box.

*PLUS+1 GUIDE dialog box example*



2230

**SYSTEM CONTEXT  
 (CONTINUED)**


**Service tool interface (continued)**

Simply click the drop down box on the right and select the actual hardware that is in your system. The reason for this is that the CAN-ID of the numeral 0 (zero) on the left doesn't match the CAN-IDs that are in your system. You need to tell it where the I/O module that you are selecting is located.

Next, you can click on the Parameter function for your I/O module in the *diagnostic navigator*. This will bring up a parameter list for the I/O module.

This parameter screen will allow you to view and change all of the configuration data for the I/O module.

*PLUS+1 GUIDE parameter list screen example*



2231

Any change of the communication parameters requires a restart of the I/O device for the changes to take effect.

**SYSTEM DESIGN**


**CAN-ID**

To minimize the number of CAN identifiers (CAN-ID) used, each I/O device uses just one CAN-ID to transmit data.

To run several devices on one network, each needs a different CAN-ID. After production all units start with the same standard default addressing mode. In the default addressing mode the devices scan the CAN-shield pin at startup and measure the voltage level at this pin. The CAN-ID is set based on this voltage. The default startup configuration is designed to create no conflicts with existing higher layer protocols in regards to the CAN-ID usage.

The addressing mode can be changed with the service tool to a set of default identifiers.

*Default configuration flow chart*



2325

**DECOMPOSITION DESCRIPTION**

The default startup configuration of I/O devices is designed to create as few conflicts as possible with existing higher layer protocols in regards to the CAN-ID usage. Due to the restricted CAN-ID range, the system will use the first data byte as a kind of sub-identifier.

Non time-critical messages and configuration messages use a special sub-identifier (0xFF) to enter a new page of commands. In this page the second data byte works as a sub-command.

**CAN-ID USAGE**


The I/O device can provide up to three different ways of using the CAN-ID.

**Variable identifier usage define with CAN-shield**

In the default configuration the system uses 11-bit identifiers according to CAN2.0 Part A. The usage of 11-bit identifiers means that the communication happens in the proprietary area of SAE J1939. To work in parallel on a CAN-open bus, the addressing scheme works on PDO (DS301).

The CAN-open default PDOs (CAN-IDs) are defined with a function code (bit 10...bit 7) and the node ID (bit 6...bit 0).

*PDO CAN-ID*



<b>P</b>	4 bits – PDO
<b>N</b>	7 bits - node ID

*PDOs defined*

PDO1 Tx	0x180+node ID
PDO1 Rx	0x200+node ID
PDO2 Tx	0x280+node ID
PDO2 Rx	0x300+node ID
PDO3 Tx	0x380+node ID
PDO3 Rx	0x400+node ID
PDO4 Tx	0x480+node ID
PDO4 Rx	0x500+node ID

CAN-open allows the node ID to range from 1 to 127.

The I/O devices will use PDO1 Tx *to transmit* and PDO2 Rx *for receive*. This avoids collision if someone in a proprietary system uses a node ID larger than 127.

*PDO Node ID usage*

- The node ID consists of 7 bits. The node ID is divided into two sections
- a) to address the requirements of different devices on the same network
  - b) so that one device is able to listen to more than one MC

**CAN-IDENTIFIER USAGE  
 (CONTINUED)**

*PDO CAN-ID with divided node-id*

Most significant bit

Least significant bit

10	9	8	7	6	5	4	3	2	1	0
P	P	P	P	N1	N1	N1	N1	N0	N0	N0

*Bit definition*

<b>P</b>	4 bits - PDO
<b>N1</b>	4 bits - node ID defined by voltage
<b>N0</b>	3 bits - node ID defined for multi MC receive communication

*N0 definition*

N0 is always set to zero for the PDO1 Tx message. N0 is also zero for the standard PDO2 Rx message, but it is possible to apply the mask value to receive all possible configurations for N0.

*N0 usage in PDO*

<b>N0</b>	<b>Tx</b>	<b>Rx</b>
0x00	Default, valid	Default, valid
0x01	Invalid	Only with masking
0x02	Invalid	Only with masking
0x03	Invalid	Only with masking
0x04	Invalid	Only with masking
0x05	Invalid	Only with masking
0x06	Invalid	Only with masking
0x07	Invalid	Only with masking

*N1 definition*

N1 is always assigned at start-up by scanning the analog/shield input. The input range is divided into 16 equal sections, each with a size of 300 mV, starting at 0 V. Any voltage higher than 4.5 Vdc will be interpreted as the highest input value.

*N1 calculation*

<b>AD-Input low value (mV)</b>	<b>AD-Input high value (mV)</b>	<b>N1</b>	<b>N1 (hex)</b>	<b>N1 (hex pos)</b>	<b>Tx</b>	<b>Rx</b>
0	299	0	0x00	0	0x0180	0x0300
300	599	1	0x01	0x08	0x0188	0x0308
600	899	2	0x02	0x10	0x0190	0x0310
900	1199	3	0x03	0x18	0x0198	0x0318
1200	1499	4	0x04	0x20	0x01A0	0x0320
1500	1799	5	0x05	0x28	0x01A8	0x0328
1800	2099	6	0x06	0x30	0x01B0	0x0330
2100	2399	7	0x07	0x38	0x01B8	0x0338
2400	2699	8	0x08	0x40	0x01C0	0x0340
2700	2999	9	0x09	0x48	0x01C8	0x0348
3000	3299	10	0x0A	0x50	0x01D0	0x0350
3300	3599	11	0x0B	0x58	0x01D8	0x0358
3600	3899	12	0x0C	0x60	0x01E0	0x0360
3900	4199	13	0x0D	0x68	0x01E8	0x0368
4200	4499	14	0x0E	0x70	0x01F0	0x0370
4500	—	15	0x0F	0x78	0x01F8	0x0378

**CAN-IDENTIFIER USAGE  
 (CONTINUED)**

**Predefined identifier usage with fixed N1**

In this configuration the N1 portion of the CAN identifier is predefined by Sauer-Danfoss. It can be adjusted by the OEM with the PLUS+1 service and diagnostic tool.

**Fixed identifier usage**

This special configuration works only with fixed identifiers. These identifiers are configurable with the diagnostic tool. Also in this configuration it is possible to apply a mask for receiving messages. It is also possible to select between 11 bit and 29 bit identifiers.

**KWP2000 NODE and  
 NET ASSIGNMENTS**

In addition to the I/O protocol the I/O devices also need to support the PLUS+1 service and diagnostic tool protocol. This is based on KeyWord Protocol 2000 (KWP2000.) Basic parameters for this are the *node* and *net* number. The following sections describe how these numbers are assigned.

**KWP2000 node number**

The node number is assigned by using N1 as the KWP2000 node number as shown below in variable identifier and predefined identifier addressing mode:

*KWP2000 node number*

Most significant bit				Least significant bit			
7	6	5	4	3	2	1	0
X	N1	N1	N1	N1	X	X	X

X	Not used = 0
N1	4 bits - node ID defined by voltage or with fixed value

**KWP2000 net number**

The *net number* is stored as a parameter in the non-volatile memory and can be modified with the PLUS+1 service and diagnostic tool.

**LED HANDLING**

To simplify system diagnostics the I/O device will use its LEDs, if available, to indicate different status conditions.

**Red LED**

The red LED indicates outgoing message traffic from the I/O device. The LED toggles its state with every successfully transmitted frame.

If the device's CAN-bus goes into a *bus off* condition then the LED will be permanently on.

**Green LED**

The green LED indicates that the I/O device is seeing incoming message traffic. The LED toggles its state with every successfully received frame. If no messages are received for more than 10 seconds, then the LED starts to blink at a one Hertz rate. Time critical messages and messages which have to be used all the time are implemented with a sub identifier which has a value from 0 to 0xFE.



PLUS+1™ CAN I/O Module Communications  
Technical Information  
Notes



## Our Products

Open circuit axial piston pumps  
Gear pumps and motors  
Fan drive systems  
Closed circuit axial piston pumps and motors  
Bent axis motors  
Hydrostatic transmissions  
Transit mixer drives  
Hydrostatic transaxles  
Electrohydraulics  
Integrated systems  
Microcontrollers and software  
PLUS+1™ GUIDE  
Displays  
Joysticks and control handles  
Sensors  
Orbital motors  
Inverters  
Electrohydraulic power steering  
Hydraulic power steering  
Hydraulic integrated circuits (HIC)  
Cartridge valves  
Directional spool valves  
Proportional valves

## Sauer-Danfoss Mobile Power and Control Systems – Market Leaders Worldwide

Sauer-Danfoss is a comprehensive supplier providing complete systems to the global mobile market.

Sauer-Danfoss serves markets such as agriculture, construction, road building, material handling, municipal, forestry, turf care, and many others.

We offer our customers optimum solutions for their needs and develop new products and systems in close cooperation and partnership with them.

Sauer-Danfoss specializes in integrating a full range of system components to provide vehicle designers with the most advanced total system design.

Sauer-Danfoss provides comprehensive worldwide service for its products through an extensive network of Global Service Partners strategically located in all parts of the world.

Local address:

Sauer-Danfoss (US) Company  
2800 East 13th Street  
Ames, IA 50010, USA  
Phone: +1 515 239-6000  
Fax: +1 515 239 6618

Sauer-Danfoss ApS  
DK-6430 Nordborg, Denmark  
Phone: +45 7488 4444  
Fax: +45 7488 4400

Sauer-Danfoss GmbH & Co. OHG  
Postfach 2460, D-24531 Neumünster  
Krokamp 35, D-24539 Neumünster, Germany  
Phone: +49 4321 871-0  
Fax: +49 4321 871 122

Sauer-Danfoss-Daikin LTD.  
Shin-Osaka TERASAKI 3rd Bldg. 6F  
1-5-28 Nishimiyahara, Yodogawa-ku  
Osaka 532-0004, Japan  
Phone: +81 6 6395 6066  
Fax: +81 6 6395 8585